

City of Unalaska
Request for Proposals
Generator Installation
Parks, Culture, and Recreation – Library Building
Addendum 2, March 19, 2026

Addendum 2

Owner: City of Unalaska

Project: Library Generator Installation

Date: March 19, 2026

Questions & Answers

Q1: Has a load study been completed prior to issuing this RFP, stating this generator can handle the load and the 200A ATS can be placed inside adjacent to MDP to intercept the feed coming from the Main Disconnect?

A1: A load study has been completed. The city requests that the contractor provide a 600 amp ATS to match the Library's 600 amp service.