ADDENDUM NUMBER: 1

To Contract Documents for:

Unalaska Backflow Prevention Project DPW Project No. 15401/Contract No.: 15401-01

Prepared for:
City of Unalaska
Department of Public Works
1035 E. Broadway Avenue
Unalaska, Alaska 99685

By Stantec Architecture Inc. 725 E. Fireweed Lane, Suite 200 Anchorage, AK 99503-2245 Phone 907.276.4245 Fax 907.258.4653

June 10, 2016

Please acknowledge receipt of this Addendum No. 1 in the appropriate blanks on the bid form.

The following corrections, changes, additions, deletions, revisions, and/or clarifications are hereby made a part of the contract documents for the **UNALASKA BACKFLOW PREVENTION PROJECT**. In case of conflicts between this Addendum and previously issued documents, this Addendum shall take precedence.

This addendum consists of the following:

Page(s) 1 of 5 Addendum Language, 2 pages Section 00 00 03 "Invitation to Bid" Site Visit Instructions, 2 pages. Section 00 03 00 "Bid Form" page 8, 1 page.

BIDDING REQUIREMENTS

- AD1-1 Section 00 00 30 "Invitation to Bid": **REVISE** the second paragraph on page 2 of 2 to read "A prebid conference will be held on **June 21, 2016** at 2:00 p.m. at the City of Unalaska Department of Public Works. Bidders may join by telephone using the following call-in number: 1-888-363-4734, Passcode 1258939. A site visit by all bidders is strongly recommended. The City will facilitate a site visit on **June 22 and 23, 2016** to sites with restricted access. See site visit information following this Section."
- AD1-2 Section 00 03 00 "Bid Form": **REPLACE** page 8 of this section in its entirety.

Addendum No.: 1

Project Name: Unalaska Backflow Prevention Project

Client Project No.: DPW Project No. 15401/Contract No.: 15401-01

SPECIFICATIONS

AD1-3 Section 00 01 00 "Instructions to Bidders", Item 16: **ADD** new paragraph 16. J to read "J. The Contract will initially be awarded as a limited 45 day notice to proceed in order to allow the procurement of long lead time materials and initial mobilization. This period will be followed by a full notice to proceed and the contract times specified in 00 05 00 "Standard Form of Agreement" Article 2.1."

- AD1-4 Section 01 00 00 "General Requirements", 1.13B: **DELETE** paragraph in its entirety.
- AD1-5 Section 31 00 00 "Earthwork", 3.12A: **REVISE** to read "Remove surplus excavation, unusable material, trash, and debris, and legally dispose of them off project site."

DRAWINGS

- AD1-6 General Note, this applies to sheets 3.01-3.03, 4.02, 5.01-5.09, 5.11-5.13, 5.15-5.17, 5.19-5.24: Any reference to Unalaska Department of Public Utilities (DPU) Standard Detail 60-6 is to include all components and installation requirements indicated in detail (i.e. straight pipe lengths upstream and downstream meter, strainer placarding and blowdown valve thread locker, spigot, etc).
- AD1-7 Sheet 5.02 "KELTY FIELD": **ADD** note under New Work to read "Provide 1-inch meter and required transitions from 1-1/2-inch piping. Valves, strainer, RPBA, piping and appurtenances are to be 1-1/2-inch."
- AD1-8 Sheet 5.13 "CITY LIBRARY-DOMESTIC": **ADD** note under New Work to read "Provide 1-inch meter and required transitions from 1-1/2-inch piping. Valves, strainer, RPBA, piping and appurtenances are to be 1-1/2-inch."
- AD1-9 Sheet 5.15 "MUSEUM OF THE ALEUTIANS": **ADD** note under New Work to read "Provide 1-inch meter and required transitions from 1-1/2-inch piping. Valves, strainer, RPBA, piping and appurtenances are to be 1-1/2-inch."
- AD1-10 Sheet 5.19 "SCHOOL 4 PLEX": **ADD** note under New Work to read "Provide 1-inch meter and required transitions from 1-1/4-inch piping. Valves, strainer, DCVA, piping and appurtenances are to be 1-1/4-inch."
- AD1-11 Sheet 5.20 "AIRPORT TERMINAL": **ADD** note under New Work to read "Provide 2-inch meter and required transitions from 1-1/2-inch piping. Valves, strainer, RPBA, piping and appurtenances are to be 1-1/2-inch."
- AD1-12 Sheet 5.23 "OLD POWER HOUSE": **ADD** note under New Work to read "Valves, meter, strainer, RPBA, piping and appurtenances provided to comply with DPU standard detail 60-6 shall be 1-inch. Provide required transitions to reconnect to existing water service and to pipe branches serving building."
- AD1-13 Sheet 5.24 "PUBLIC WORKS UTILITIES BUILDING": **ADD** note under New Work to read "Provide 2-inch meter and required transitions from 1-1/2-inch piping. Valves, strainer, RPBA, piping and appurtenances are to be 1-1/2-inch."

END OF ADDENDUM NUMBER: 1

Unalaska Backflow Prevention Project – DPW Project No. 15401 Site Visits

DPW will provide access to listed facilities where plumbing work is being performed. These facilities are not accessible at other times without the express permission and physical presence of a DPW/DPU representative.

Meet at the Eagles Elementary School parking lot at 9:30am Wednesday June 22, 2016. City personnel will provide access to facilities in the order shown below. Lunch break starts at 12pm and we will reconvene at the next site at 1:30pm. We expect 10-30 minutes per site. Day ends at 4pm.

If we do not make it through all of the facilities we will reconvene at 9:30 am Thursday June 23, 2016 at the next site.

Eagles Elementary School

High School Wood Shop

High School

High School Alternative Building

Kelty Field

Public Works UPHC

Public Works Utilities Building

School 4Plex

Tutiakoff Field

City Baler Facility

Burma Road Chapel

PCR

Library

City Hall

Public Safety

Museum of the Aleutians

Sitka Spruce Park

Amaknak Fire Hall

Airport Terminal

Old Powerhouse

New Powerhouse

US Coast Guard Shack

Carl E. Moses Small Boat Harbor

Landfill Bay Avenue Vault

Bobby Storrs Small Boat Harbor A and B Floats

The following facilities will not be shown by DPW because they are accessible at any time to bidders:

Multi-Purpose Court South Channel Tideflex East Point Tideflex Spit Dock Tideflex

The following facilities will not be shown by DPW because they only require device certification:

Well House 1
Well House 2
Well House 3
Pyramid Water Treatment Plant
UPCH
Wastewater Treatment Plant
Public Works Wash Bay
Bobby Storrs Small Boat Harbor – C Float
Unalaska Marine Center
Light Cargo Dock
CEM A Float
CEM B Float
CEM C Float

Unalaska Backflow Prevention Project SECTION 00 03 00 DPW Project No.: 15401/Contract No..: 15401-01 BID FORM

BID BOND	
KNOW ALL MEN BY THESE PRESENTS: that	
(Name of Contractor)	
(Ivalie of Contractor)	
(Address of Contractor)	
as Principal, hereinafter called Principal, and	
(Name of Surety)	
(Address of Surety)	
a corporation duly organized under the laws of the State of Alaska as Surety, hereinafter called	Surety,
are held and firmly bound unto	
City of Unalaska (Name of Owner)	
P.O. Box 610, Unalaska, AK 99685	
as Obligee, hereinafter called Obligee, in the sum of	
Dollars, (\$) for the payment of which sum well and truly to be made	
said Principal and the said Surety, bind ourselves, our heirs, executors, administrators, successors and assigns, ly and severally, firmly by these presents.	joint-
y and severally, fifting by these presents.	
WHEREAS, the Principal has submitted a bid for the City of Unalaska, UNALASKA BACKFLOW	
PREVENTION PROJECT, located in Unalaska, Alaska.	
NOW THEREFORE, if the Obligee shall accept the bid of the Principal and the Principal shall enter into a Co	ontract
with the Obligee in accordance with the terms of such bid, and give such bond or bonds as may be specified	
bidding or Contract Documents with good and sufficient surety for the faithful performance of such Contract a	
the prompt payment of labor and material furnished in the prosecution thereof, or in the event of the failure	of the
Principal to enter such Contract and give such bond or bonds, if the Principal shall pay to the Obligee the diff	erence
not to exceed the penalty hereof between the amount specified in said bid and such larger amount for which t	
ligee may in good faith contract with another party to perform the Work covered by said bid, then this obli	gation
shall be null and void, otherwise to remain in full force and effect.	
Signed and Sealed this day of 2016	
(Witness) (Principal) Seal	
(Title) Seal	

Bid Documents 00 03 00 - 8 June 1, 2016

END OF DOCUMENT 00 03 00